

3 ENVIRONMENT						3.1 FIRE SAFETY - <i>The Regulatory Reform (Fire Safety) Order, 2005</i> - page 2				
Observation	Elements of Risk		Degree of Risk			Comments	CONTROL MEASURES		Completed	
	SEV'TY	LIKEH'D	LOW	MED	HIGH		Action Required	Target Date	Verified by	Date
11	Fire exit doors not operable from the inside. Push-bar mechanism not working.									
12	Fire exit doors do not open outwards to full 90 degrees.									
13	Fire extinguishers not present / not working / incorrect type.									
14	Access to fire extinguishers obstructed.									
15	Fire extinguishers not regularly checked / serviced (<i>check status labels</i>).									
16	Smoke detectors not present / not working / not regularly checked. Records not available.									
17	Fire alarms not working properly.									
18	Fire alarm connections to the Fire Station / Fire Officer not functioning properly.									
19	Fire alarms not regularly tested. Records not available.									
20	Access to fire hose reels obstructed.									

Risk Assessments carried out by: _____

Date(s): _____